bcc: Endler, Gerstman, Levy, Corrado, Weinstein

Fireproofing
File WTC 113.00

June 16, 1970

Mario G. DiBono
136 Liberty Street
New York, N.Y.

Re: WTC 113.00
Spray-on Fireproofing

Gentlemen:

Be advised that in accordance with contract documents the colored overspray sealer being used to seal truss spray-on fireproofing is to cover all ceiling areas of spray-on fireproofing which come into contact with the ceiling plenum to prevent erosion due to air velocities.

The above is to be performed at no cost to Forya.

Very truly yours,

Tishman Realty & Construction Co., Inc. (Agent)

Bert Weinstein
Project Manager

BW:ck

cc-Horti, Werner, P/A

P0001219

PLAINTIFF'S EXHIBIT PX-618